

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1621:101

Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: Anvil International, Inc. 110 Corporate Dr, Suite 10, Portsmouth, NH 03802-3180
Contact: Michael Horgan (401) 349-3020 FAX (401) 233-8142

DESIGN: Model AE7722-3A butterfly valves, sizes 2, 2 ½, 3, 4, 5, 6, 8, and 10 inch in the grooved end type of maximum rated pressures of 175 and 300 psi. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as a butterfly valve for use with fire sprinkler systems. Refer to listee's Installation Instruction Manual for details.

Corrected 02-03-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**